

Selections:	PWS: MT0000156 - LOCKWOOD WATER AND SEWER DISTRICT State: MT										
	UCMR Minimum Reporting Level (MRL, µg/L)	Non-Regulatory Health-Based Ref Conc (µg/L)	Total Results	Results ≥ MRL	Results > Health-Based Ref Conc	Percent of Results > Health-Based Ref Conc	Total PWSs with Results	PWSs with Results ≥ MRL	PWSs with Results > Health-Based Ref Conc	Percent of Large PWSs with Results > Health-Based Ref Conc	Percent of Small PWSs with Results > Health-Based Ref Conc
lithium	9	10	4	4	4	100.0%	1	1	1	-	100.0%
PFBA	0.005	6	4	0	0	0.0%	1	0	0	-	0.0%
PFHxA	0.003	3	4	0	0	0.0%	1	0	0	-	0.0%
PFDA	0.003	-	4	0	-	-	1	0	-	-	-
11CI-PF3OUdS	0.005	-	4	0	-	-	1	0	-	-	-
8:2 FTS	0.005	-	4	0	-	-	1	0	-	-	-
4:2 FTS	0.003	-	4	0	-	-	1	0	-	-	-
6:2 FTS	0.005	-	4	0	-	-	1	0	-	-	-
ADONA	0.003	-	4	0	-	-	1	0	-	-	-
9CI-PF3ONS	0.002	-	4	0	-	-	1	0	-	-	-
NFDHA	0.02	-	4	0	-	-	1	0	-	-	-
PFEESA	0.003	-	4	0	-	-	1	0	-	-	-
PFMPA	0.004	-	4	0	-	-	1	0	-	-	-
PFMBA	0.003	-	4	0	-	-	1	0	-	-	-
PFDoA	0.003	-	4	0	-	-	1	0	-	-	-
PFHpS	0.003	-	4	0	-	-	1	0	-	-	-
PFHpA	0.003	-	4	0	-	-	1	0	-	-	-
PFPeS	0.004	-	4	0	-	-	1	0	-	-	-
PFPeA	0.003	-	4	0	-	-	1	0	-	-	-
PFUnA	0.002	-	4	0	-	-	1	0	-	-	-
NEtFOSAA	0.005	-	4	0	-	-	1	0	-	-	-
NMeFOSAA	0.006	-	4	0	-	-	1	0	-	-	-
PFTA	0.008	-	4	0	-	-	1	0	-	-	-
PFTrDA	0.007	-	4	0	-	-	1	0	-	-	-